


GENERAL NOTES

- Curb ramp type B shall not be used on new construction, but only when field conditions warrant for existing sidewalk alterations.
- (2) These dimensions are based on a 6" curb height, and shall be proportionally adjusted for other curb heights.
- (3) The bottom edge of the curb ramp shall be flush with the edge of the adjacent pavement and gutter line.
- 4 Landing areas at the top of curb ramps shall have maximum cross slope of 1:50 in any direction. Where site infeasibility on a 3R project precludes a landing slope of 1:50 in any direction, the slope perpendicular to the curb face shall not exceed 1:50.
- (5) If site infeasibility on a 3R project precludes construction as shown, the landing width may be decreased to 3'-0 minimum and running slope of the curb ramp may be increased to a maximum of 10:1 for 6" of rise.



APRIL 1995
STANDARD DRAWING NO.E 604-SWCR-04

DETALS PLACED IN THIS FORMAT 7-27-99

STATE OF S

DESIGN STANDARDS ENGINEER

ORIGIANLLY APPROVED